



# Certificate

Certificate-No.: DMT ANB 20231001, based on DMT test report no. PPS2 00 063 23  
Validity: 2023-10-05 - 2028-10-05

Conformity of an aerosol treatment device for commercial kitchens according to  
**DIN EN 16282-8:2017-12**

We confirm to the company

**Air-Filter Kft.**  
**1033 Budapest**  
**Szőlőkert köz 9.**  
**Hungary**

for the UV-C aerosol treatment device for commercial kitchens, **Type „UVO-C 760K”** of manufacturer **“R-FILTER”** (Hungary) the **Conformity with the requirements of DIN EN 16282-8:2017-12 (Equipment for commercial kitchens – Components for ventilation in commercial kitchens – Part 8: Installations for treatment of aerosol; Requirements and testing)**. The aerosol treatment device **“UVO-C 760K”** can be labeled according DIN EN 16282-8:2017-04, chapter 4, as:

**„Aerosol treatment system EN 16282-8-H3”**

**Essen, 2023-10-05**

---

(Dr. Renschen)

Plant & Product Safety - Laboratory for Air Hygiene

---

(Dipl.-Ing. Joh. Schamberg)

DMT GmbH & Co. KG  
Am TÜV 1, 45307 Essen

**TÜVNORDGROUP**